



AHMEDABAD MUNICIPAL CORPORATION

FIRE AND EMERGENCY SERVICES DEPARTMENT

DANAPITH FIRE STATION (HEADQUARTERS), NR.AMC OFFICE, DANAPITH, AHMEDABAD

NOC Number: NOC101816042021

Category: School

NOC Issue Date: 26/05/2021

NO OBJECTION CERTIFICATE

This is to certify that management of M/s **CALORX PUBLIC SCHOOL** located at **BEHIND SHIVANAND APARTMENT LANE NEXT TO H.P. PETROL PUMP , KK NAGAR ROAD,GHATLODIA,AHMEDABAD** has installed necessary Fire Protection Equipments mentioned below.

Hydrant System With

- * Main Pump - (1 Nos.)
- * Hose Box with Hose - (2 Nos.)
- * Hydrant Point / Valve - (2 Nos.)
- * Fire Bridge Inlet (2/4 Way) - (1 Nos.)
- * Hose Reel - (10 Nos.)
- * Short Branch - (2 Nos.)
- * Sprinklers System Installed Yes
- * Manual Call Point - (8 Nos.)
- * Fire Alarm System Installed Yes

Fire Extinguishers

- * 6 Kg. Capacity ABC Type - (9 Nos.)
- * 4.5 Kg. Capacity Co2 Type - (6 Nos.)
- * 9 Liter Capacity Water/Co2 Type - (2 Nos.)

All the Fire Protection Equipments installed shall be maintained in working order throughout the validity period of this certificate.

This Certificate is valid for ONE YEAR from the date of issue.



(Rajesh Bhatt)

Chief Fire Officer (I/c)

Ahmedabad Municipal Corporation